

- 1. Darling 4. A.P. Smith
- 2. Kennedy 5. Matthews
- 3. Mueller 6. R.D. Wood

Dallastown-Yoe Water Authority



Hydrant Record
Year: 2018

| ID # | Note | Location | Type | Year Made | Feed | Pressure (psi) | | Flow (gpm) | Flushed (min) | Needs Repair | Last Inspected | Comments/Notes |
|---------|------|---|------|-----------|------|----------------|----------|------------|---------------|--------------|----------------|--|
| | | | | | | Static | Residual | | | | | |
| D138 | | Colonial Dr. & April Ln. | 2 | 1973 | | | | | | | | Call Donald Sarge prior to flushing, 320 S Lombard, DOES NOT DRAIN |
| D139 | | Intersection of Colonial Dr. & Kirsta Ln. | 2 | 1973 | 6" | | | | | | " | |
| D140 | | Intersection of Carrie Dr. & Kirsta Ln. | 2 | 1974 | 6" | | | | | | " | HARD TO TURN |
| X | * | <i>Blow-off on Kirsta Ln.</i> | | | 6" | | | | | | " | In the front yard of 261 Kirsta Ln NO LONGER EXISTS. IT IS NOW JUST A VALVE |
| YT 181 | | 622 Carrie Dr. | 1 | 1996 | 6" | | | | | | " | |
| YT 182 | | Kirsta Ln. at Wilson Ave. | 2 | 1972 | 6" | | | | | | " | HARD TO TURN |
| YT BO18 | | <i>Blow-off on Wilson Ave.</i> | | | 6" | | | | | | " | In the front yard of 675 Wilson Ave |
| YT 187 | | Intersection of S. Park St. & Mellinger Dr. | 1 | 1967 | 6" | | | | | | " | |
| YT 188 | | Rydell Dr. in cul-de-sac | 1 | 1991 | 6" | | | | | | " | NST on Hydrant |
| YT 183 | | 764 Summit Dr. | 1 | 1966 | 6" | | | | | | " | |
| YT 185 | | 753 Ridgelyn Dr. | 1 | 1978 | 6" | | | | | | " | |

1. Darling 4. A.P. Smith
2. Kennedy 5. Matthews
3. Mueller 6. R.D. Wood

Dallastown-Yoe Water Authority



Hydrant Record
Year: 2018

| ID # | Note | Location | Type | Year Made | Feed | Pressure (psi) | | Flow (gpm) | Flushed (min) | Needs Repair | Last Inspected | Comments/Notes |
|---------|------|---|------|-----------|------|----------------|----------|------------|---------------|--------------|----------------|---|
| | | | | | | Static | Residual | | | | | |
| YT 186 | | Ridgelyn Dr. in cul-de-sac | 1 | | 6" | | | | | | | |
| YT 184 | | Ridgelyn Dr. at Summit Dr. | 1 | 1978 | 6" | | | | | | | |
| YT BO19 | | <i>Blow-off on S. Park St. at Sherry Dawn Dr.</i> | | | 6" | | | | | | | |
| YT BO20 | | <i>Blow-off at the end of Sherry Dawn Dr.</i> | | | 4" | | | | | | | |
| YT BO21 | | <i>Blow-off behind 755 Mockingbird Ln.</i> | | | 2" | | | | | | | |
| YT 189 | | Windrush Dr. at S. Park St. | 1 | 1996 | 6" | | | | | | | |
| YT BO22 | | <i>Blow-off on S. Park St. below Aldinger Dr.</i> | | | 8" | | | | | | | |
| YT 191 | * | 498 S. Park St. | 1 | 1995 | 8" | | | | | | | Hydrant is located on Aldinger Dr. |
| YT BO23 | | <i>Blow-off on Aldinger Dr.</i> | | | 8" | | | | | | | |
| YT 190 | | 755 Windrush Dr. | 1 | 1994 | 6" | | | | | | | Call Wyndridge 818-5112 |
| YT BO24 | J | <i>Blow-off in Windrush Dr. cul-de-sac</i> | | | 6" | | | | | | | Call DT schools, Hairy (Hap) 717-501-6540 CALL Dr. Roth (Dentist) 244-4094 |
| YT 177 | J | Melvale Rd. at S. Pleasant Ave. | 1 | 1975 | 6" | | | | | | | CALL MEDICAL CENTERS DFPC = 851-1300, D MED. ASSOC. 244-4531 |
| YT BO25 | J | <i>Blow-off at 610 S. Pleasant Ave.</i> | | | 6" | | | | | | | |
| YT 178 | | S. Pleasant Ave. at Blymire Rd. | 2 | 1981 | 6" | | | | | | | Hard to turn |
| YT 179 | | <i>Markey Trucking, 847 S. Pleasant Ave.</i> | 1 | 2013 | 6" | | | | | | | Call before blow off (call WHO?) STOP IN AT MARKEYS TRUCKING |
| YT 180 | | <i>Hydrant @ 885 S. Pleasant Ave.</i> | 1 | | 6" | | | | | | | Darling 2013 |
| YT BO26 | * | <i>Blow-off on Blymire Rd</i> | | | 6" | | | | | | | Blow-off is located below the cemetery. |
| YT 227 | | <i>Hydrant @ D-town Family Medical</i> | 1 | 2011 | 6" | | | | | | | |
| YT 173 | | Hydrant @ Lions Dr. & Blymire | 3 | 2011 | 6" | | | | | | | |
| YT 174 | | Lion's Lane at dead end | 1 | 1989 | 6" | | | | | | | |
| YT * | | <i>110 Brand Dr.</i> | 2 | 1969 | 6" | | | | | | | Prior to flushing, close valve at Brandon Dr. cul-de-sac. ↓ |

- 1. Darling 4. A.P. Smith
- 2. Kennedy 5. Matthews
- 3. Mueller 6. R.D. Wood

Dallastown-Yoe Water Authority



Hydrant Record
Year: 2018

| ID # | Note | Location | Type | Year Made | Feed | Pressure (psi) | | Flow (gpm) | Flushed (min) | Needs Repair | Last Inspected | Comments/Notes |
|------------|------|-------------------------------------|------|-----------|------|----------------|----------|------------|---------------|--------------|----------------|---|
| | | | | | | Static | Residual | | | | | |
| 175 | | 117 Brant Dr. | 2 | 1977 | 0 | | | | | | | ↓ |
| YT BO27 | | Blow-off in Wolsey Dr. cul-de-sac | | | 6" | | | | | | " | Open about 1/3 -will flood houses on Thomas ↓ |
| YT 176 | * | New School Ln.2 | 1 | 1989 | 6" | | | | | | " | Flush, then re-open Brandon Dr. valve. |
| YT BO28 | | Blow-off Blymire Rd | | | 6" | | | | | | " | Call Tom Brant before flushing 717-891-2331 |
| YT 165 | | Frederick Dr. at Blymire Rd. | 1 | 1975 | 6" | | | | | ✗ | " | #s might be off because leaks bad around steamer cap, threads are messed up but works/seemed OK to me |
| YT 164 | | 435 Frederick Dr. | 1 | 1975 | 6" | | | | | ✗ | " | Steamer cap difficult to get off-Grease it |
| YT 166 | * | 401 Dartha Dr. | 2 | 1979 | 6" | | | | | ✗ | " | Leaks badly @ bonnet |
| YT 167 | | 431 Dartha Dr. | 2 | 1979 | 6" | | | | | | " | |
| YT 168 | | Dartha Dr. at Troy Rd. | 1 | 1995 | 6" | | | | | | " | |
| YT 171 | | Intersection of Kent Dr. & Troy Rd. | 2 | 1979 | 6" | | | | | | " | |
| YT BO29 | | Blow-off in Kent Dr. cul-de-sac | | | 6" | | | | | | " | |
| YT 170 | | 260 Troy Rd. | 2 | 1979 | 6" | | | | | | " | Hard to turn open |
| YT 169 | | 229 Troy Rd. | 2 | 1979 | 6" | | | | | | " | Hard to open |
| YT 163 | | 385 Frederick Dr. | 1 | 1975 | 6" | | | | | | " | |
| YT 162 | | 220 W. Boundary Ave. | 1 | 1975 | 6" | | | | | | " | Hard to turn/takes a while to open |

- 1. Darling 4. A.P. Smith
- 2. Kennedy 5. Matthews
- 3. Mueller 6. R.D. Wood

Dallastown-Yoe Water Authority



Hydrant Record
Year: 2018

| ID # | Note | Location | Type | Year Made | Feed | Pressure (psi) | | Flow | | Flushed (min) | Needs Repair | Last Inspected | Comments/Notes |
|---------|------|--|------|-----------|------|----------------|----------|-------|-------|---------------|--------------|----------------|---|
| | | | | | | Static | Residual | (gpm) | (min) | | | | |
| YT 161 | | 123 Teila Dr. | 1 | 1975 | 6" | | | | | | | | |
| YT 159 | | Ridgeford Rd. at Teila Dr. | 1 | 1975 | 6" | | | | | | | | |
| YT 160 | | 239 Teila Dr. | 1 | 1975 | 6" | | | | | | ✗ | | Missing 1 top bolt |
| YT 172 | | 529 Gary Dr. | 2 | 1974 | 6" | | | | | | | | Use diffuser on back of truck washes out driveway |
| YT 148 | * | S. Franklin St. at Dallas Dr. | 1 | 1989 | 8" | | | | | | | | Place cones to slow traffic. |
| YT 149 | * | Franklin Square Dr. at S. Franklin St. | 1 | 1989 | 6" | | | | | | ✗ | | LEAKS BADLY @ BONNET Call John Slackey(carwash) 757-4719 |
| YT 150 | | 135 Franklin Square Dr. | 1 | 1989 | 6" | | | | | | | | |
| YT 151 | | Franklin Square Dr. at Perring Dr. | 1 | 1989 | 6" | | | | | | | | |
| YT 152 | | 285 Franklin Square Dr. | 1 | 1989 | 6" | | | | | | | | |
| YT 153 | | 325 Franklin Square Dr. | 1 | 1989 | 6" | | | | | | | | Leaks around turn on valve at top real bad when opened |
| YT 154 | | Pulaski Place entrance | 1 | 1989 | 6" | | | | | | | | Floods Driveway |
| YT 155 | * | 444 Pulaski Place ₁ | 1 | 2004 | 6" | | | | | | | | Close valve #1 designated on map C below, then flush. Leave valve closed. |
| YT 156 | | 472 Pulaski Place | 1 | 2004 | 6" | | | | | | | | ↓ |
| YT 155 | * | 444 Pulaski Place ₂ | 1 | 2004 | 6" | | | | | | | | Re-open valve #1, close valve #2, then flush for 2 nd time. Re-open valve #2. |
| YT 157 | | 435 Ridgeford Rd. | 1 | 1975 | 6" | | | | | | | | |
| YT 158 | | Leaderton Drive | 1 | 1975 | 6" | | | | | | | | 212 Leaderton Dr, very hard to turn |
| YT BO30 | | BO Honey Valley & Franklin | | | 6" | | | | | | | | |
| YT 126 |) | 2952 Honey Valley Rd. | 2 | 1975 | 8" | | | | | | | | Call R.A. Martin prior to flushing. Phone 741-1124(CAN'T HARDLY TURN) |
| YT 125 | | 2904 Honey Valley Rd. | 2 | 1974 | 8" | | | | | | | | CALL Sandra Warren Sweitzer 246-3090 SEE MAP C, HARD TO TURN |